

NFPA 72 Smoke Detector Spacing Requirements

Robert P. Schifilitti, P.E.
Fax +1 781.944.9300
Voice +1 781.942.7500
email rps@rpsa-fire.com

rpsa
Fire Protection Engineers

Smoke Detectors: Solid Joist and Beam Construction

- *Prior to the 1996 edition*
 - 33.3% reduction in spacing perpendicular to solid joisted ceilings
 - Reduction in spacing perpendicular to solid beamed ceilings is required but not specified

rpsa
Fire Protection Engineers

Smoke Detectors: Solid Joist and Beam Construction

- *Joists and beams have non-structural definitions*
 - Depth of the obstruction at the ceiling
 - Spacing between the obstructions.
- *Some combinations of d and W require detectors in each bay or pocket.*

rpsa

Fire Protection Engineers

Smoke Detectors: Solid Joist and Beam Construction

- *1996 International Fire Detection Research Project (IFDRP)*
- *Based on CFD modeling by NIST of complex ceiling geometries*
- *New spacing proposals to NFPA 72*
- *Underlying performance benchmark:*
 - Detection of a 100 kW flaming fire

rpsa
Fire Protection Engineers

Results in many more detectors being required on common ceiling configurations, such as waffle pan ceilings and in mill type construction.


1999 2-3.4.6 Smoke Detectors: Solid Joist and Beam Construction

- *In 1996 edition all solid joisted ceilings were treated the same as beams*
 - Resulted in detectors in joist pockets for $h > 12$ ft or $d > 1$ ft
- *In 1999 edition only joists greater than 1 ft deep are treated as beams*
- *But...*

rpsa
Fire Protection Engineers

Task group worked to try and change the requirements, reducing numbers for solid joisted ceilings.


But the proposal left joisted ceilings with depths 1 ft or less and ceilings greater than 12 ft unaddressed.



The paragraphs mix requirements for placement (on the joist or beam or in the pocket) with requirements for spacing.

Analyze spacing or number required separately from location.


Looking at spacing, or number of detectors required...



Smoke Detection Joisted Ceilings

- *In the 1996 edition*
Joisted = Beamed
- *In the 1999 edition*
 - Section 2-3.4.6
Joisted = Beamed only if $d > 1$ foot

rpsa
Fire Protection Engineers





So, lets say that by the definitions in 1-4 you have a joisted ceiling (more than 4" deep and 3 ft or less apart).

Should the joists be treated as joists or as beams as far as smoke detection spacing is concerned?

Until and unless there is a TIA, use 1996 edition and treat as beams.

Smoke Detection 2-3.4.6.1 Beamed Ceilings





Is it reasonable to follow the code and design a system to respond to a 100 kW fire?

Remember, there is no “credit” for smoke produced prior to open flaming.

?Making the ceiling smooth may be less expensive.

Long term life cycle costs.